



U.S. Micro-Solutions, Inc. * 1075 South Main Street, Suite 104 * Greensburg, PA 15601
 Phone: (724) 853-4047 Fax: (724) 853-4049
www.usmslab.com



Customer Name:	U.S. Micro Solutions, Inc.	Sample Date:	May 23, 2017
Customer Address:	1075 South Main Street, Suite 104 Greensburg, PA 15601	Date Received:	May 24, 2017
Customer Phone:	(724) 853-4047	Date of Report:	May 30, 2017
PO Number:		Fax:	(724) 853-4049
Project Name/Number:	HPC Sample Report	Attention:	
		Analysis Date:	May 24, 2017
		Sample Time:	12:15
		Analysis Time (hrs):	26.8

Customer sample numbers below are uniquely identified by prefixing Laboratory # 12345-17

Liquid Sample(s) for Heterotrophic Plate Count - Analytical Method SM 9215B*

Sample Number	Media	Location	Results of Microbial Analysis
1	R2A	Kitchen	<1 CFU/mL Raw Count: <1
AS = 1 CFU/mL (Volume examined: 2.2 mL)			
2	R2A	Restroom	5,000 estimated CFU/mL Estimated Raw Count: 500
AS = 10 CFU/mL (Volume examined: 2.2 mL)			
3	R2A	Shower Room	48 CFU/mL Raw Count: 48
AS = 1 CFU/mL (Volume examined: 2.2 mL)			

Sample Report

Notes:

CFU/mL = colony forming units per milliliter, AS = analytical sensitivity.
 Results relate only to the samples tested. Results are reported as calculated.

*Rice, E.W., R.B. Baird, A.D. Eaton, and L.S. Clesceri. Pour Plate Method 9215B. Standard Methods for the Examination of Water and Wastewater, 22nd Ed. Washington, DC: APHA, AWWA, WEF, 2012.

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager: Herbert Layman
 Herbert Layman, BS, SM, CIEC

Contact: Sharon Fanchalsky, Laboratory Supervisor: 877-876-4276

End of Report