



Customer Name:	U.S. Micro-Solutions, Inc.	Sample Date:	March 1, 2021
Customer Address:	302 Unity Plaza Latrobe, PA 15650	Date Received:	March 2, 2021
Customer Phone:	724-853-4047	Date of Report:	March 13, 2021
PO Number:		Fax:	
Project Name/Number:	Water Tank Failure	Attention:	
		Analysis Date:	March 2, 2021

Customer sample numbers below are uniquely identified by prefixing Laboratory # 12345-21

Water/Liquid Sample(s) for BART Culture - Analytical Method MIC 43

Sample Number	Media	Sample Description	Results of Microbial Analysis
1	IRB-BART	Tap water sample 2	Negative for Iron-Related Bacteria
	SRB-BART		
	SLYM-BART		
		Agressivity: N/A	Negative for Sulfate-Reducing Bacteria
		Agressivity: N/A	Negative for Slime-Forming Bacteria
2	IRB-BART	Tap water sample 1	Positive for Iron-Related Bacteria
	SRB-BART		
	SLYM-BART		
		Agressivity: Moderate	Negative for Sulfate-Reducing Bacteria
		Agressivity: N/A	Positive for Slime-Forming Bacteria
		Agressivity: Not Aggressive	

Sample Report

Notes:

Samples are in good condition unless otherwise noted. Results are reported as Positive or Negative. Results relate only to the samples tested as received.

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager: Deanna L. Kiska
 Deanna L. Kiska, Ph.D.

End of Report