



U.S. Micro-Solutions, Inc. * 302 Unity Plaza * Latrobe, PA 15650
Phone: (724) 853-4047 Fax: (724) 853-4049 AIHA-LAP, LLC EMLAP # 103009
www.usmslab.com

Customer Name: U.S. Micro Solutions, Inc. Sample Date: January 9, 2021
Customer Address: 302 Unity Plaza Date Received: January 11, 2021
Latrobe, PA 15650 Date of Report: February 21, 2021
Customer Phone: (724) 853-4047 Fax: (724) 853-4049
PO Number: Attention:
Project Name/Number:

Customer sample numbers below are uniquely identified by prefixing Laboratory # 12345-21

Water Sample(s) for Isolation of *Mycobacterium* spp. - Analytical Method USMS MIC 15

Sample Number	Media	Sample Description	Results of Microbial Analysis
1	Middlebrook 7H11 Agar	Sink	
Volume examined: 100 mL			Positive - <i>Mycobacterium mucogenicum</i>
2	Middlebrook 7H11 Agar	Ice Machine	
Volume examined: 100 mL			Positive - <i>Mycobacterium avium</i>
3	Middlebrook 7H11 Agar	Faucet	
AS = <1 CFU/mL (Volume examined: 200 mL)			No <i>Mycobacterium</i> spp. isolated

Sample Report

Notes:

Samples are in good condition unless otherwise noted. Results relate only to the samples tested as received. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant.

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager: Deanna L. Kiska

Deanna L. Kiska, Ph.D.

End of Report