



Customer Name:	U.S. Micro Solutions, Inc.	Sample Date:	January 9, 2023
Customer Address:	302 Unity Plaza Latrobe, PA 15650	Date Received:	January 11, 2023
		Date of Report:	February 1, 2023
Customer Phone:	(724) 853-4047	Fax:	(724) 853-4049
PO Number:		Attention:	John Smith
Project Name/Number:	Mycobacteria Sample Report		

Customer sample numbers below are uniquely identified by prefixing Laboratory # 12345-23

Water Sample(s) for Isolation of *Mycobacterium* spp. - Analytical Method MIC 15

Sample Number	Media	Sample Description	Results of Microbial Analysis
1	NTM	Sink	
AS = 0.5 CFU/mL (Volume examined: 100 mL)			25 CFU/mL - <i>Mycobacterium mucogenicum</i> isolated
2	NTM	Ice Machine	
AS = 0.5 CFU/mL (Volume examined: 100 mL)			25 CFU/mL - <i>Mycobacterium avium</i> isolated
3	NTM	Faucet	
AS = 0.5 CFU/mL (Volume examined: 100 mL)			No <i>Mycobacterium</i> spp. isolated

Sample Report

Notes:

CFU/mL = colony forming units per milliliter, AS = analytical sensitivity

Samples are in good condition unless otherwise noted. Results relate only to the samples tested as received. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant. Organisms are listed in order of predominance.

When providing duplicates of this report, the document should be provided in total and not in section. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager:

Deanna L. Kiska

Deanna L. Kiska, Ph.D.

End of Report